



Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services
Sepoy Bazar, P.O.:- Medinipur, P.S.:- Kotwali, Pin:- 721101

Memo no.:FSR/0125186231500207

Date: 04-12-2023

From:
Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services

To: BOGCHARI P.T.T.I. under trust RATNAKAR TRUSTEE SOCIETY
MOUZA - MUKTICHAK(BOGCHARI), J.L. NO. - 440, L.R. PLOT NO. - 40,41, KHATIAN NO. 108, P.S. - KESHPUR.
DIST - PASCHIM MEDINIPUR, PIN - 721150

Sub: Fire Safety Certificate for Existing construction of G+III Storied College Building the name in style "BOGCHARI P.T.T.I under RATNAKAR TRUSTEE SOCIETY" under group of Educational Building at Mouza - Muktichak(Bogchari), J.L. No. - 440, L.R. Plot No. - 40, 41, Khatian No. 108, P.S. - Keshpur. Dist. - Paschim Medinipur, PIN - 721150.

This is in reference to your application no. 0125189231500116 dated 16-10-2023 regarding the Fire Safety Certificate for Existing construction of G+III Storied College Building the name in style "BOGCHARI P.T.T.I under RATNAKAR TRUSTEE SOCIETY" under group of Educational Building at Mouza - Muktichak(Bogchari), J.L. No. - 440, L.R. Plot No. - 40, 41, Khatian No. 108, P.S. - Keshpur. Dist. - Paschim Medinipur, PIN - 721150.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

- 1.Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Drive way.
- 2.Directiona! sign and escape route shall be displayed prominently.
- 3.To eliminate risk of fire hazards, good housekeeping both for insides and outsides of the Building shall be strictly maintained.
- 4.The interior finish decoration of the building shall be made with low flame spread material confirming I.S specification.
- 5.The notice of Fire Fighting and Evacuation with EXIT sign from the building shall be prepared and displayed at all vulnerable places of the building before taking occupancy.

6.The employees and security staff shall be conversant with installed Fire Fighting Equipment's of the building and to operate in the event of Fire and Testing.

7.Mock Fire practice and evacuation system shall be performed periodically with participation of all occupants of building.

8. First-Aid Fire Fighting system shall be provided as per I.S Specification.

9.Arrangement shall have to be made for regular checking, testing, and maintenance of all Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.

10.If required the old line shall have to be replace with new line the cables shall always be laid in M.S. Conduct pipes continuously bounded to the earth.

11.Periodical flashing of water from the Hydrants pipe line shall be made to maintain the efficient working performance of above mention system.

12.The Fire Safety Audit to be conducted a regular interval and to be recorded in the fire Prevention maintenance register.

13.Existing electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling and ducts.

14.A Fire control room with close circuit T.V system will have to be installed which will observe all the floor of the building.

15.Transformer and switch Gear room shall be protected with automatic Co2 or D.C.P Fire Extinguisher conforming I.S Specification.

16.A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.

17.This FSC is valid for Three year has to be renewed every Three year from the date of issue of this.

18.Each Three year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all the life & Fire Safety arrangements and installation of the building.

N.B: - No addition and alteration without prior permission of Fire & Emergency Services. Otherwise, this Fire Safety Certificate will be treated as cancelled.

Memo No.:FSR/0125186231500207